

Day	pH	Alk	Phos	Other	Y/N
1	7.84	60.8			Y
2					
3					
4					
5					
6					
7					
8	7.74	60.8			Y
9					
10					
11					
12					
13					
14					
15					
16	8.39	65.6			Y
17					
18					
19					
20					
21					
22	8.19	62.4			Y
23					
24					
25					
26					
27					
28					
29					
30	8.07	59.2			Y
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-A

PWS ID 4100506

NEAHKAHNE WATER DISTRICT

Sample period: JAN / 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

7.0

Alk

50.0

 (Alkalinity)

Print Name: Scott A Morrill

Signature: Scott A Morrill

Date & Phone#: 1-31-24 (Sun) (503) 804-4649

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0
