

Day	pH	Alk	Phos	Other	Y/N
1	7.55	59.2			Y
2					
3					
4					
5					
6					
7					
8	7.67	60.8			Y
9					
10					
11					
12					
13					
14					
15	7.68	60.8			Y
16					
17					
18					
19					
20					
21					
22	8.15	63.4			Y
23					
24					
25					
26					
27					
28					
29	7.93	58.4			Y
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100506**

**NEAHKAHNIE WATER DISTRICT**

Sample period: Apr. / 2024  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0
Alk	50.0 (Alkalinity)

Print Name: Scott A Merrill

Signature: Scott A Merrill

Date & Phone#: 4-29-24 (503) 804-4649

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0