

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1					
2			~	***************************************	
3 4					
4					
5	7.44	669			Y
6	•				7
7					
8					
9					
10					
11					
12	7.38	680			Y
13					
14			20		
15					
16					
17					
18					
19	7.44	68.8			4
20					
21			*		
22					
23					
24					
25					
26	7.41	68.8			4
27					
28					
29					
30					
31					
(No =	N = Ex	cursior) Tota	ıl N's	D

< <have< th=""><th>County: Tillamook Agency: TILLAMOOK COUNTY</th></have<>	County: Tillamook Agency: TILLAMOOK COUNTY				
minimums been met for	ENTRY POINT				
this day?	EP-A				
PWS ID 4100506					
NEAL	HKAHNIE WATER DISTRICT				
Sample pe	eriod: Aug 2024 Month/Year				

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Minimum Water Quality Parameter(s) as set by State:	
pH 7.0 Alk 50.0 (Alkalinity)	
Print Name: Seatt A Morrill	
Signature: Les H Whatel	
Date & Phone#: 4-31-2024 (503)804-7	164

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

⊢*Reference*