

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.69	60.0			Y
7					
8					
9					
10					
11					
12					
13	7.69	60.8			Y
14					
15					
16					
17					
18					
19					
20	7.81	59.2			Y
21					
22					
23					
24					
25					
26					
27	7.53	60.8			Y
28					
29					
30					
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-A

PWS ID 4100506

NEAHKAHNIE WATER DISTRICT

Sample period: Jan. 2025
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0
Alk 50.0 (Alkalinity)

Print Name: Phil Chick

Signature: Phil Chick

Date & Phone#: 1-30-25 503-739-2348

Send to DWP within 10 days after end of
sampling period