

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.54	60.4			Y
4					
5					
6					
7					
8					
9					
10	7.57	60.8			Y
11					
12					
13					
14					
15					
16					
17	7.38	62.8			Y
18					
19					
20					
21					
22					
23					
24	7.70	64.0			Y
25					
26					
27					
28					
29					
30					
31					

<<Have  
minimums  
been met for  
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100506**

**NEAHKAHNIE WATER DISTRICT**

Sample period: FEB. 2025  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 

7.0
-----

  
Alk 

50.0
------

 (Alkalinity)

Print Name: Phil Chick  
Signature: Phil Chick  
Date & Phone#: 2-28-25 503.739.2348

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 

0
---

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>