

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1					
2					
2	7.78	62.8			
4					
5					
6					
7					
8					
9					
10	7.43	59.6			
11					
12					
13				i.i	
14					
15					14
16					
17	7.52	60.4			
18					
19					
20					
21					
22					
23					
24	7.45	62.8			
25					
26	100				
27					
28					
29					
30					
31					

<<Have minimums been met for this day? County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-A

PWS ID 4100506

NEAHKAHNIE WATER DISTRICT

Sample period: March 2025

Number of excursions during this month: ___

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

-Reference
Minimum Water Quality Parameter(s) as set by State:
pH 7.0 Alk 50.0 (Alkalinity)
The Charles

Print Name: 100 Chick

Signature: 210 Clark

Date & Phone#: 4/9/25 503 739 2348

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/