

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.47	78.0			Y
8					
9					
10					
11					
12					
13					
14	7.54	77.2			Y
15					
16					
17					
18					
19					
20					
21	7.47	79.2			Y
22					
23					
24					
25					
26					
27					
28	7.44	78.8			Y
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-A

PWS ID 4100506

NEAHKAHNIE WATER DISTRICT

Sample period: July 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0
Alk 50.0 (Alkalinity)

Print Name: Jeremy Rex
Signature: Jeremy Rex
Date & Phone#: 7/31/25 206-919-4291

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0