

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8	7.48	79.2			Y
9					
10					
11					
12					
13					
14					
15	7.48	77.2			Y
16					
17					
18					
19					
20					
21					
22	7.48	76.8			Y
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-A

PWS ID 4100506

NEAHKAHNE WATER DISTRICT

Sample period: Sept. 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0
Alk 50.0 (Alkalinity)

Print Name: Jeremy Rex
Signature: Jeremy Rex
Date & Phone#: 9/30/25 (206) 919-4291

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0