

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.36	80.0		Y	
7					
8					
9					
10					
11					
12					
13	7.80	81.2		Y	
14					
15					
16					
17					
18					
19					
20	7.33	80.0		Y	
21					
22					
23					
24					
25					
26					
27	7.37	80.4		X	
28					
29					
30					
31					

(No = N = Excursion) **Total N's**

<<Have  
minimums  
been met for  
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100506**

**NEAHKAHNIE WATER DISTRICT**

Sample period: Oct. 2025

Month/Year

**Number of excursions during this month:** 0

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH	7.0
Alk	50.0

(Alkalinity)

Print Name: Jeremy Rex

Signature: Jeremy Rex

Date & Phone#: 10/31/25 (206) 919-4291

Send to DWP within 10 days after end of  
sampling period