

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.65	52.8			Y
2					
3					
4					
5					
6					
7					
8	7.78	56.8			Y
9					
10					
11					
12					
13					
14					
15	7.63	55.2			Y
16					
17					
18					
19					
20					
21					
22	7.60	53.6			Y
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT
EP-B**

PWS ID 4100506

NEAHKAHNE WATER DISTRICT

Sample period: Feb/2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

7.0

Alk

50.0

 (Alkalinity)

Print Name: Scott A Merrill

Signature: Scott A Merrill

Date & Phone#: 3/2/21 (503) 804 4649

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0