

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.72	58.4			Y
5					
6					
7					
8					
9					
10					
11					
12	7.51	57.6			Y
13					
14					
15					
16					
17					
18					
19	7.41	56.8			Y
20					
21					
22					
23					
24					
25					
26	7.59	57.6			Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-B**

**PWS ID 4100506**

**NEAHKAHNIE WATER DISTRICT**

Sample period: April / 2021  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 

7.0
-----

  
 Alk 

50.0
------

 (Alkalinity)

Print Name: Scott A Merrill  
 Signature: Scott A Merrill  
 Date & Phone#: 4.30.2021 (503) 804-4649

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0