

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.59	57.6			Y
4					
5					
6					
7					
8					
9					
10	7.47	55.2			Y
11					
12					
13					
14					
15					
16					
17	7.76	58.4			Y
18					
19					
20					
21					
22					
23					
24	7.83	59.2			Y
25					
26					
27					
28					
29					
30					
31	7.76	56.8			Y

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**  
**EP-B**

**PWS ID 4100506**  
**NEAHKAHNE WATER DISTRICT**

Sample period: January / 2022  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0
Alk	50.0 (Alkalinity)

Print Name: Scott A. Merrill  
 Signature: Scott A. Merrill  
 Date & Phone#: 1.31.2022 503-804-4649

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0