

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.56	56.8			Y
7					
8					
9					
10					
11					
12					
13	7.59	57.6			Y
14					
15					
16					
17					
18					
19					
20	7.45	63.2			Y
21					
22					
23					
24					
25					
26					
27	7.66	60.8			Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY
ENTRY POINT
EP-B
PWS ID 4100506
NEAHKAHNE WATER DISTRICT
 Sample period: Feb/2023
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference
Minimum Water Quality Parameter(s) as set by State:
 pH

7.0

 Alk

50.0

 (Alkalinity)

Print Name: Scott A Merrill
 Signature: Scott A Merrill
 Date & Phone#: 3.1.2023 (503) 804-4649

Send to DWP within 10 days after end of sampling period

0 = N = Excursion) Total N's

0
