

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13	7.89	64.0			Y
14					
15					
16					
17					
18					
19					
20	7.77	62.4			Y
21					
22					
23					
24					
25					
26					
27	7.83	60.8			Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT
EP-B**

**PWS ID 4100506
NEAHKAHNE WATER DISTRICT**

Sample period: March / 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0
Alk	50.0 (Alkalinity)

Print Name: Scott A Merrill

Signature: Scott A Merrill

Date & Phone#: 3.31.23 (503) 804.4649

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's