

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.63	70.4			
3					
4					
5					
6					
7	7.71	74.2			Y
8					
9					
10					
11					
12					
13					
14					
15					
16	7.73	69.6			Y
17					
18					
19					
20					
21					
22					
23	7.65	69.6			Y
24					
25					
26					
27					
28					
29					
30	7.90	72.8			Y
31					

10 = N = Excursion) **Total N's** 4

<<Have
minimums
been met for
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-B

PWS ID 4100506

NEAHKAHNE WATER DISTRICT

Sample period: Sept. / 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0
Alk 50.0 (Alkalinity)

Print Name: Scott A. Mercier

Signature: Scott A. Mercier

Date & Phone#: 9-30-24 (503) 804-4649

Send to DWP within 10 days after end of
sampling period