

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.74	70.4			Y
8					
9					
10					
11					
12					
13					
14	7.50	72.8			Y
15					
16					
17					
18					
19					
20					
21	7.55	71.2			Y
22					
23					
24					
25					
26					
27					
28	7.48	71.6			Y
29					
30					
31					

(No = N = Excursion) **Total N's** D

<<Have
minimums
been met for
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-B

PWS ID 4100506

NEAHKAHNIE WATER DISTRICT

Sample period: Oct / 2024
Month/Year

Number of excursions during this month: D

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0
Alk	50.0 (Alkalinity)

Print Name: Scott A Morrill

Signature: Scott A Morrill

Date & Phone#: 10.31.24 (503) 801-4649

Send to DWP within 10 days after end of
sampling period