

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.45	71.6			Y
5					
6					
7					
8					
9					
10					
11	7.53	67.2			Y
12					
13					
14					
15					
16					
17					
18	7.43	70.0			Y
19					
20					
21					
22					
23					
24					
25	7.61	68.0			Y
26					
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-B

PWS ID 4100506

NEAHKAHNIE WATER DISTRICT

Sample period: Nov 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0
Alk 50.0 (Alkalinity)

Print Name: Scott Merrill

Signature: Scott Merrill

Date & Phone#: 11-30-24 (503) 801-4649

Send to DWP within 10 days after end of
sampling period