

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1					
2					
2					
4					
5					
6					
7	7.85	644			Y
8					
9					
10				l l	
11					
12					
13					
14	7.76	60.4			1
15					
16					
17					
18					
19					
20					
21	7.93	61.6			Y
22 23					
23					
24					
25					
26					
27					
28	7.74	62.0			Y
29	-				
30			0 9		
31					
10 = 1	1 = Exc	cursion) Tota	l N's	0

< <have minimums been met for this day?</have 	County: Tillamook Agency: TILLAMOOK COUNTY ENTRY POINT EP-B					
PWS ID 4100506 NEAHKAHNIE WATER DISTRICT						
Sample pe	eriod: April 2025 Month/Year					

Number of excursions during this month: __

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference	
Minimum Water Quality Parameter(s) as set by State:	
pH 7.0 Alk 50.0 (Alkalinity)	
Print Name: Jeremy Prex	
Signature: Jenny Rev	
Date & Phone#: 5/2/25 706-919-429	1
Send to DWP within 10 days after end of	

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

sampling period