

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.74	62.4			✓
6					
7					
8					
9					
10					
11					
12	7.68	68.8			✓
13					
14					
15					
16					
17					
18					
19	7.71	67.2			✓
20					
21					
22					
23					
24					
25					
26	7.76	72.0			✓
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

ENTRY POINT

EP-B

PWS ID 4100506

NEAHKAHNIE WATER DISTRICT

Sample period: May 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0
Alk	50.0 (Alkalinity)

Print Name: Jeremy Rex

Signature: Jeremy Rex

Date & Phone#: 5/3/25 (206) 919-4291

Send to DWP within 10 days after end of
sampling period