

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11	7.61	79.6			Y
12					
13					
14					
15					
16					
17					
18	7.60	74.0			Y
19					
20					
21					
22					
23					
24					
25	7.60	72.8			Y
26					
27					
28					
29					
30					
31					

<<Have  
minimums  
been met for  
this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-B**

**PWS ID 4100506**

**NEAHKAHNIE WATER DISTRICT**

Sample period: August 2025  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.0  
Alk 50.0 (Alkalinity)

Print Name: Jeremy Rex

Signature: Jeremy Rex

Date & Phone#: 8/31/25 (206) 919-4291

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0