

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.9	78			Y
7					
8					
9					
10					
11					
12					
13	7.3	58			Y
14					
15					
16					
17					
18					
19					
20	7.3	56			Y
21					
22					
23					
24					
25					
26					
27	7.5	72			Y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT
EP-B**

PWS ID 4100506

NEAHKAHNE WATER DISTRICT

Sample period: March / 2026
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

7.0

 Alk

50.0

 (Alkalinity)

Print Name: Nicholas Theoharis
 Signature: [Signature]
 Date & Phone#: 4/3/26 503-812-1516

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

--