Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1	MS-1 (office)A	7.51	57.6			Y
2	MS-5 (NEST)B	7.63	58.4			Y

(N = No = Excursion) **Total N's** 0

<Has sample met the minimum(s)?

County: Tillamook Agency: TILLAMOOK

DISTRIBUTION

PWS ID 4100506

NEAHKAHNIE WATER DISTRICT

Sample Period: March / 2021
Month/Year

Sample Frequency: Every 36 months

Distribution Samples required: 2

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH	7.0	
Alk	50.0	*(Alkalinity)*

Print Name: Scott A Merrill

Signature: Scott A Merrill

Date: 3.25.2021

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/