



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3				Y
2	7.2				Y
3	7.2				Y
4	7.2				Y
5	7.2				Y
6	7.3				Y
7	7.2				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.3				Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.3				Y
17	7.3				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.4				Y
24	7.4				Y
25	7.4				Y
26	7.3				Y
27	7.3				Y
28	7.4				Y
29	7.4				Y
30	7.3				Y
31	7.3				Y

<<Have minimums been met for this day?

County:
Lane

Agency: Regio

ENTRY POINT

EP-A

PWS ID 4100507

MAPLETON WATER DISTRICT

Sample period: JANUARY - 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

RECEIVED

FEB 3 2021

Data Mgmt & Compliance
Drinking Water Program

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.1

Print Name: Terry W Saubert
Signature: *Terry W Saubert*
Date: 2-1-21

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period