



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2	7.7				Y
3	8.2				Y
4					
5	8.2				Y
6	7.81				Y
7	7.94				Y
8					
9	7.78				Y
10	7.76				Y
11					
12	7.64				Y
13	7.66				Y
14	7.53				Y
15	7.93				Y
16	7.80				Y
17	7.44				Y
18					
19	7.61				Y
20	7.41				Y
21					
22	7.41				Y
23	7.60				Y
24					
25					
26	7.57				Y
27	7.84				Y
28	7.44				Y
29	7.78				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00507

System Name: Mapleton Water District

Entry Point: EP-A

Sample Period: April / 2021  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For DHS use only*

**Minimum Water Quality Parameters as set by**

pH 7.1

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

Print Name: GARREN FRIEDEMANN

Signature:

Date: 7/15/21

Send to DWP within 10 days after end of sampling period

\*No = N = Excursion) Total N's 0