



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8				Y
2	7.8				Y
3	8.0				Y
4	7.8				Y
5					
6					
7	7.9				Y
8	7.8				Y
9					
10	7.9				Y
11	7.7				Y
12					
13					
14	8.0				Y
15	7.8				Y
16					
17	7.7				Y
18	7.7				Y
19	7.8				Y
20					
21	7.8				Y
22	7.8				Y
23					
24	7.9				Y
25	7.8				Y
26	7.8				Y
27					
28	7.8				Y
29	7.8				Y
30	7.7				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00507

System Name: Mapleton Water District

Entry Point: EP-A

Sample Period: June / 2021
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH 7.1

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: GARDEN Friedemann

Signature: *Dawn*

Date: 7/5/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0