

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	8.0				Y
4	7.9				Y
5	8.0				Y
6	7.4				Y
7	7.9				Y
8	8.0				Y
9	7.9				Y
10	8.0				Y
11	8.0				Y
12	8.0				Y
13	8.0				Y
14	8.0				Y
15	7.9				Y
16	8.0				Y
17	7.7				Y
18	7.7				Y
19	7.9				Y
20	8.0				Y
21	8.0				Y
22	8.0				Y
23	8.0				Y
24	8.0				Y
25	8.0				Y
26	8.0				Y
27	7.8				Y
28	7.9				Y
29	7.9				Y
30	7.9				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Mapleton Water District

Entry Point: EP-A

Sample Period: September 2021

Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 10/6/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's