

Day	pH	Alk	Phos	Other	Y/N
1	7.97				Y
2	7.97				Y
3	7.92				Y
4	7.93				Y
5	7.93				Y
6	7.97				Y
7	7.97				Y
8	7.94				Y
9	7.96				Y
10	7.93				Y
11	7.98				Y
12	8.0				Y
13	7.98				Y
14	7.92				Y
15	8.0				Y
16	7.97				Y
17	7.93				Y
18	7.96				Y
19	8.0				Y
20	7.95				Y
21	7.97				Y
22	7.77				Y
23	7.92				Y
24	7.90				Y
25	7.96				Y
26	7.94				Y
27	7.94				Y
28	7.81				Y
29	7.77				Y
30	7.96				Y
31	7.97				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00507

System Name: Mapleton Water District

Entry Point: EP- A

Sample Period: October 2021
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.1

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 11/5/21

Send to DWP within 10 days after end of sampling period