

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2	8.0				Y
3	8.0				Y
4	8.3				Y
5	7.9				Y
6	7.9				Y
7	8.0				Y
8	7.9				Y
9	8.0				Y
10	7.7				Y
11	OFF				Y
12	7.3				Y
13	7.9				Y
14	7.9				Y
15	OFF				Y
16	7.8				Y
17	OFF				Y
18	OFF				Y
19	8.5				Y
20	8.5				Y
21	8.0				Y
22	8.3				Y
23	8.1				Y
24	8.1				Y
25	8.1				Y
26	8.0				Y
27	8.1				Y
28	8.2				Y
29	8.2				Y
30	8.2				Y
31	N/A				N/A

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: Mapleton Water District

Entry Point: EP-A

Sample Period: November 2021  
 Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.1"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 12/6/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's