

Day	pH	Alk	Phos	Other	Y/N
1	8.3				Y
2	8.3				Y
3	8.2				Y
4	8.3				Y
5	8.2				Y
6	8.2				Y
7	8.3				Y
8	8.4				Y
9	8.4				Y
10	8.3				Y
11	8.3				Y
12	8.3				Y
13	8.3				Y
14	8.3				Y
15	8.3				Y
16	8.3				Y
17	8.3				Y
18	8.2				Y
19	8.2				Y
20	8.3				Y
21	8.3				Y
22	8.3				Y
23	8.3				Y
24	8.2				Y
25	8.2				Y
26	7.5				Y
27	7.9				Y
28	8.2				Y
29	8.2				Y
30	8.2				Y
31	8.3				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 00507

System Name: Mapleton Water District

Entry Point: EP-A

Sample Period: January / 2022
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.1

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 2/8/22

Send to DWP within 10 days after end of sampling period