

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.2				Y
2	8.4				Y
3	8.4				Y
4	8.4				Y
5	8.3				Y
6	8.4				Y
7	8.4				Y
8	8.5				Y
9	8.5				Y
10	8.5				Y
11	8.5				Y
12	8.5				Y
13	8.4				Y
14	8.4				Y
15	7.9				Y
16	8.3				Y
17	8.4				Y
18	8.3				Y
19	8.5				Y
20	8.4				Y
21	8.4				Y
22	8.3				Y
23	8.4				Y
24	8.4				Y
25	8.4				Y
26	8.4				Y
27	8.4				Y
28	8.5				Y
29	8.5				Y
30	8.5				Y
31	8.4				Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: Mapleton Water District

Entry Point: EP-A

Sample Period: MARCH 2022

Month/Year

Number of excursions\* during this month: \_\_\_\_\_

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH   
 Alk  (Alkalinity)  
 PO4  (Orthophosphate)  
 Other  (\_\_\_\_\_)

Print Name: DARREL LOCKARD

Signature: [Signature]

Date: 4/10/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's