

Day	pH	Alk	Phos	Other	Y/N
1	8.73				Y
2	8.36				Y
3	8.01				Y
4	8.41				Y
5	8.40				Y
6	8.37				Y
7	8.09				Y
8	8.37				Y
9	8.40				Y
10	8.43				Y
11	8.39				Y
12	8.37				Y
13	7.95				Y
14	8.74				Y
15	8.33				Y
16	8.41				Y
17	8.42				Y
18	8.40				Y
19	8.13				Y
20	8.40				Y
21	8.36				Y
22	8.42				Y
23	8.41				Y
24	8.49				Y
25	8.40				Y
26	8.38				Y
27	8.43				Y
28	8.35				Y
29	8.32				Y
30	8.38				Y
31	8.45				Y
					0

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	5	0	7
---	---	---	---	---

System Name: Mapleton Water District

Entry Point: EP-A

Sample Period: May 2022

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.1

Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

(_____)

Print Name: Richard A. Howard Sr.

Signature: Richard A. Howard Sr.

Date: June 10, 2022

Send to DWP within 10 days after end of sampling period