



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.3				Y
2	8.4				Y
3	8.4				Y
4	8.3				Y
5	8.3				Y
6	8.3				Y
7	8.4				Y
8	8.3				Y
9	8.4				Y
10	8.2				Y
11	8.5				Y
12	8.3				Y
13	8.3				Y
14	8.1				Y
15	off				
16	8.3				Y
17	8.3				Y
18	8.3				Y
19	8.3				Y
20	8.2				Y
21	8.2				Y
22	8.2				Y
23	off				
24	8.3				Y
25	8.2				Y
26	8.2				Y
27	8.1				Y
28	8.3				Y
29	8.6				Y
30	8.4				Y
31					

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	5	0	7
System Name:	<u>Mapleton Water District</u>						
Entry Point:	<u>WTP-A</u>						
Sample Period:	<u>Jun-22</u>						
	Month / Year						

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	<input type="text" value="7.1"/>
Alk	<input type="text"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Thursday, July 7, 2022

(NO=N=Excursions) **Total N's**

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381