

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Sili	Y/N
1	8.4				yes
2	8.4				yes
3	8.4				yes
4	8.3				yes
5	8.3				yes
6	8.3				yes
7	8.4				yes
8	8.3				yes
9	8.4				yes
10	8.2				yes
11	8.5				yes
12	8.3				yes
13	8.3				yes
14	8.1				yes
15					no
16	8.3				yes
17	8.3				yes
18	8.3				yes
19	8.3				yes
20	8.2				yes
21	8.2				yes
22	8.2				yes
23					no
24	8.3				yes
25	8.2				yes
26	8.2				yes
27	8.1				yes
28	8.3				yes
29					no
30					no
31					no
(NO=	0				

<< Have minimums
been met for this
day?

PWS ID:	4	1	0	0	5	0	7		
Name: Mapleton Water District									
oint.			WT	Ρ-Δ					

**ENTRY POINT** 

System Name: Mapleton Water District
Entry Point: WTP-A
Sample Period: Mar 2023
Month / Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS	use only			
Minimum Water Quality Parameters as set by State:				
pH Alk PO4	7.1	(Alikalinity) (Orthophosphate)		
Sili		(Silicate)		

Print Name:	Dave Terrusa			
Signature:	/S/ Digital Signature			
Date:	8 April, 2023			

Send to DHS within 10 days after end of sampling period DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381