

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Sili	Y/N
1	7.2				yes
2	7.3				yes
3	7.2				yes
4	7.2				yes
5	7.1				yes
6	7.3				yes
7	7.2				yes
8	7.2				yes
9	7.3				yes
10	7.3				yes
11	7.3				yes
12	7.3				yes
13	7.2				yes
14	7.2				yes
15	7.3				yes
16	7.3				yes
17	7.3				yes
18	7.3				yes
19	7.3				yes
20	7.3				yes
21	7.3				yes
22	7.3				yes
23	7.3				yes
24	7.3				yes
25	7.3				yes
26	7.4				yes
27	7.3				yes
28	7.3				yes
29	7.3				yes
30	7.3				yes
31	7.3				yes
(NO=	N=Ex	cursio	ns) Tot a	al N's	0

<< Have minimums
been met for this
day?

PWS ID:	4	1	0	0	5	0	7	
Name:	,	Mai	plet	on l	Nati	or D	ietr	ict

ENTRY POINT

System Name:	Mapleton Water District			
Entry Point:	WTP-A			
Sample Period:	May-23			
	Month / Year			

Number of excursions* during this month: 0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS	use only	-	
Minimum Water Quality Parameters as set by State:			
рН	7.1]	
Alk		(Alikalinity)	
PO4		(Orthophosphate)	
Sili		(Silicate)	
		-	

Print Name:	Dave Terrusa			
Signature:	/S/ Dave Terrusa			
Date:	10 June, 2023			

Send to DHS within 10 days after end of sampling period DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381