

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рΗ	Alk	Phos	Sili	Y/N	<< Have mi	nimums		ENTRY	POINT
1	7.3				yes	been met fo	or this	PWS ID:	4 1 0 0	5 0 7
2	7.3				yes	day?		L	<u> </u>	
3	7.3				yes		System	n Name:	Mapleton	Water District
4	7.3				yes		Entry F	oint:	WTP-A	A Contraction of the second se
5	7.3				yes		Sample	e Period:		Jun-23
6	7.3				yes			•	Month	/ Year
7	7.3				yes					
8	7.4				yes	Number of excursions* during this month: 0				
9	7.4				yes	(Count the number of days when any WQP was less then the				
10	7.4				yes	n	ninimum	required)		
11	7.4				yes					
12	7.3				yes					
13	7.4				yes	Total excursions during the previous 5 months: 0				
14	7.4				yes	(Over 9 excursions in 6 months is a violation. Entry Point and				
15	7.4				yes	Distribution excursions are cumulative)				
16	7.4				yes					
17	7.3				yes	For DHS use only				
18	7.3				yes					
19	7.4				yes				Minimum W	ater Quality
20	7.3				yes				Parameters	as set by State:
21	7.3				yes					_
22	7.4				yes				pH 7.1	
23	7.3				yes				Alk	(Alikalinity)
24	7.3				yes				PO4	(Orthophosphate)
25	7.3				yes				Sili	(Silicate)
26	7.3				yes					
27	7.3				yes					
28	7.4				yes	F	Print Na	ame:	Dav	e Terrusa
29	7.4				yes					
30	7.3				yes		Signatu	ire:	Digitally signed	
31					no					
(NO=	N=Ex	cursio	ns) Tot a	al N's	0	[[Date:		10 July, 2023	<u>-</u>

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381