



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4				yes
2	7.4				yes
3	7.4				yes
4	7.4				yes
5	7.5				yes
6	7.4				yes
7	7.4				yes
8	7.4				yes
9	7.4				yes
10	7.5				yes
11	7.5				yes
12	7.4				yes
13	7.4				yes
14	7.4				yes
15	7.4				yes
16	7.4				yes
17	7.4				yes
18	7.5				yes
19	7.4				yes
20	7.4				yes
21	7.4				yes
22	7.5				yes
23	7.4				yes
24	7.4				yes
25	7.5				yes
26	7.4				yes
27	7.4				yes
28	7.4				yes
29	7.5				yes
30	7.5				yes
31	7.4				yes

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

System Name: Mapleton Water District

Entry Point: WTP-A

Sample Period: Jul-23
Month / Year

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Dave Terrusa

Signature: _____

Date: 10 August, 2023

(NO=N=Excursions) **Total N's**