



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

| Day | pH  | Alk | Phos | Sili | Y/N |
|-----|-----|-----|------|------|-----|
| 1   | 7.4 |     |      |      | yes |
| 2   | 7.3 |     |      |      | yes |
| 3   | 7.4 |     |      |      | yes |
| 4   | 7.4 |     |      |      | yes |
| 5   | 7.4 |     |      |      | yes |
| 6   | 7.4 |     |      |      | yes |
| 7   | 7.4 |     |      |      | yes |
| 8   | 7.4 |     |      |      | yes |
| 9   | 7.4 |     |      |      | yes |
| 10  | 7.4 |     |      |      | yes |
| 11  | 7.4 |     |      |      | yes |
| 12  | 7.4 |     |      |      | yes |
| 13  | 7.4 |     |      |      | yes |
| 14  | 7.4 |     |      |      | yes |
| 15  | 7.4 |     |      |      | yes |
| 16  | 7.4 |     |      |      | yes |
| 17  | 7.4 |     |      |      | yes |
| 18  | 7.4 |     |      |      | yes |
| 19  | 7.4 |     |      |      | yes |
| 20  | 7.4 |     |      |      | yes |
| 21  | 7.3 |     |      |      | yes |
| 22  | 7.3 |     |      |      | yes |
| 23  | 7.4 |     |      |      | yes |
| 24  | 7.4 |     |      |      | yes |
| 25  | 7.3 |     |      |      | yes |
| 26  | 7.3 |     |      |      | yes |
| 27  | 7.4 |     |      |      | yes |
| 28  | 7.4 |     |      |      | yes |
| 29  | 7.4 |     |      |      | yes |
| 30  | 7.4 |     |      |      | yes |
| 31  | 7.3 |     |      |      | yes |

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID:

System Name: Mapleton Water District

Entry Point: WTP-A

Sample Period: Aug-23  
Month / Year

Number of excursions\* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH   
Alk  (Alkalinity)  
PO4  (Orthophosphate)  
Sili  (Silicate)

Print Name: Dave Terrusa

Signature: S / Dave Terrusa

Date: 8 September, 2023

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381