



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.1				yes
2	8.3				yes
3	8.4				yes
4	8.7				yes
5	7.8				yes
6	8.2				yes
7	8.2				yes
8	8.4				yes
9	8.0				yes
10	8.0				yes
11	7.9				yes
12	8.0				yes
13	8.0				yes
14	8.1				yes
15	7.9				yes
16	7.7				yes
17	8.4				yes
18	8.0				yes
19	8.3				yes
20	8.3				yes
21	8.4				yes
22	7.8				yes
23	7.7				yes
24	7.9				yes
25	8.2				yes
26	7.8				yes
27	7.8				yes
28	8.0				yes
29	7.9				yes
30	8.1				yes
31	8.6				yes

<< Have minimums been met for this day?

ENTRY POINT							
PWS ID:	4	1	0	0	5	0	7
System Name:	<u>Mapleton Water District</u>						
Entry Point:	<u>WTP-A</u>						
Sample Period:	<u>Aug-24</u>						
	Month / Year						

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 5
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.1
Alk	
PO4	
Sili	

(Alkalinity)
(Orthophosphate)
(Silicate)

Print Name: David Terrusa

Signature: /S/ David Terrusa

Date: 10 September, 2024

(NO=N=Excursions) **Total N's** 0

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381