



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.464				yes
2	7.549				yes
3	7.475				yes
4	7.457				yes
5	7.41				yes
6	7.54				yes
7	7.435				yes
8	7.527				yes
9	7.421				yes
10	7.407				yes
11	7.414				yes
12	7.41				yes
13	7.4				yes
14	7.431				yes
15	7.432				yes
16	7.503				yes
17	7.58				yes
18	7.559				yes
19	7.576				yes
20	7.561				yes
21	7.473				yes
22	7.473				yes
23	7.465				yes
24	7.423				yes
25	7.459				yes
26	7.409				yes
27	7.46				yes
28	7.381				yes
29	7.384				yes
30	7.396				yes
31	7.4				yes

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

System Name: Mapleton Water District

Entry Point: WTP-A

Sample Period: Jul-25
Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: David Terrusa

Signature: /s/ David Terrusa

Date: 2 August, 2025

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381