



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.551				yes
2	7.55				yes
3	7.542				yes
4	7.562				yes
5	7.556				yes
6	7.468				yes
7	7.519				yes
8	7.63				yes
9	7.449				yes
10	7.521				yes
11	7.524				yes
12	7.534				yes
13	7.491				yes
14	7.393				yes
15	7.582				yes
16	7.54				yes
17	7.509				yes
18	7.54				yes
19	7.527				yes
20	7.55				yes
21	7.538				yes
22	7.568				yes
23	7.195				yes
24	7.473				yes
25	7.477				yes
26	7.582				yes
27	7.568				yes
28	7.55				yes
29	7.445				yes
30	7.437				yes

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	5	0	7
---	---	---	---	---	---	---

System Name: Mapleton Water District

Entry Point: WTP-A

Sample Period: Sep-25

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.1
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: David Terrusa

Signature: /s/ David Terrusa

Date: 8 October, 2025

(NO=N=Excursions) Total N's 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381