

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.539				yes
2	7.628				yes
3	7.549				yes
4	7.53				yes
5	7.552				yes
6	7.513				yes
7	7.449				yes
8	7.534				yes
9	7.544				yes
10	7.53				yes
11	7.579				yes
12	7.557				yes
13	7.575				yes
14	7.617				yes
15	7.616				yes
16	7.526				yes
17	7.445				yes
18	7.445				yes
19	7.449				yes
20	7.449				yes
21	7.449				yes
22	7.463				yes
23	7.442				yes
24	7.453				yes
25	7.529				yes
26	7.586				yes
27	7.594				yes
28	7.861				yes
29					
30					
31					

NA
↓

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

System Name: Mapleton Water District

Entry Point: WTP-A

Sample Period: Feb-26
Month / Year

Number of excursions* during this month:
(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: DAVID R. TERRUSA

Signature: David Terrusa

Date: 9 MAR 2026

(NO=N=Excursions) Total N's