

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

County: Lane      Agency: REGI  
**ENTRY POINTS EP - D & F**  
PWS ID 4100508  
**Marcola Water District**

**Irish Well EP-D**

Day	PH	Y/N
1	—	
2	—	
3	—	
4	7.65	y
5	—	
6	—	
7	—	
8	7.45	y
9	—	
10	—	
11	—	
12	—	
13	—	
14	—	
15	—	
16	—	
17	—	
18	—	
19	—	
20	—	
21	—	
22	—	
23	7.15	y
24	—	
25	—	
26	—	
27	7.19	y
28	—	
29	—	
30	—	
31	—	
Total N's		0

(No = N = Excursion)

**Spicer Well EP-F**

Day	PH	Y/N
1	—	
2	7.70	y
3	7.76	y
4	7.65	y
5	7.81	y
6	—	
7	7.50	y
8	7.55	y
9	7.59	y
10	7.81	y
11	7.60	y
12	7.40	y
13	—	
14	7.50	y
15	7.30	y
16	7.44	y
17	7.35	y
18	7.79	y
19	7.48	y
20	7.70	y
21	—	
22	7.84	y
23	—	
24	—	
25	7.57	y
26	7.54	y
27	—	
28	—	
29	—	
30	—	
31	—	
Total N's		

\*\* Have minimums  
been met for  
this day?



Number of excursions this month, EP-D: 0

Number of excursions this month, EP-F: 2

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Minimum Water Quality  
Parameter(s) as set by State:**

**EP-D PH 7.0**

**EP-F PH 7.0**

Print Name: Jeffrey A. Moen

Signature: [Signature]

Date: 11/30/21 (12/4/21)

\*\*Send to DWP within 10 days after  
end of sampling period

Sample Period: November 2021