

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	7.39			y
2				
3				
4				
5	8.18	125		y
6	7.99			y
7	7.81			y
8				
9				
10				
11	7.68	115		y
12	8.12	120		y
13				
14				
15				
16				
17				
18				
19	7.84	120		y
20	7.86	110		y
21				
22				
23				
24	8.3	105		y
25				
26	8.09	140		y
27	7.99	140		y
28				
29				
30				
31				

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: January 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Print Name: Seth A. Moorsal

Signature: [Signature]

Date: 2-1-22

Send to DWP within 10 days after end of sampling period

Eric Carlson 2-1-22

(No = N = Excursion) Total N's



OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>