

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Comments	Y/N
1				
2	7.73	140		y
3				
4	7.69	140		y
5				
6				
7				
8	7.64	120		y
9				
10				
11	7.88	140		y
12	8.30	-		y
13				
14				
15				
16	7.60	140		y
17				
18				
19				
20				
21	7.80	140		y
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41 00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: February 2022  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months:       
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	( )

Eric Carlson 3-3-22

Print Name: Jeff Maresca

Signature: [Signature]

Date: 3/1/22

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0