

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Comments	Y/N
1	7.32	140		y
2				
3				
4				
5				
6				
7				
8	7.45	140		y
9	7.41	140		y
10				
11				
12				
13				
14				
15				
16	7.84	140		y
17	7.66	140		y
18				
19				
20				
21	7.93	140		y
22				
23	7.55	—		y
24				
25	8.12	—		y
26				
27	7.90	140		y
28	7.88	—		y
29	8.66	140		y
30				
31				

(No = N = Excursion) Total N's ☒

<<Have

minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: June 2022

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

Eric Carlson

Print Name: Jeff Mierzan

Signature: [Signature]

Date: 7/1/22

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>