

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	8.5	140		y
2				
3				
4				
5				
6	7.70	140		y
7	7.71			y
8	8.43	140		y
9				
10				
11	8.37			y
12	8.63	140		y
13	8.24	140		y
14	8.56	140		y
15	8.86	140		y
16				
17				
18	8.87	140		y
19	8.19	140		y
20	8.44	140		y
21	8.86	140		y
22	8.41	140		y
23				
24				
25	8.21	140		y
26	8.32	140		y
27	8.18	140		y
28	8.05	140		y
29	7.98	140		y
30				
31				

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: July 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0
Alk 45.0 (Alkalinity)
PO4 -- (Orthophosphate)
Other -- ()

Eric Carlson 8-3-22

Print Name: Jeff Morrison

Signature: [Signature]

Date: 8/3/22

Send to DWP within 10 days after end of
sampling period