

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2	7.80	120		y
3	7.84	120		y
4				
5				
6				
7	8.40	120		y
8				
9				
10				
11				
12				
13				
14				
15				
16				
17	7.68	120		y
18				
19				
20				
21				
22	7.83	120		y
23				
24				
25				
26				
27				
28				
29				
30				
31				

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: February 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="45.0"/>	(Alkalinity)
PO4	<input type="text" value="--"/>	(Orthophosphate)
Other	<input type="text" value="--"/>	()

Eric Carlson 3-7-23

Print Name: Jeffrey A. Moers

Signature: [Signature]

Date: 3/3/23

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

