

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1				
2	8.34	—		y
3				
4				
5				
6	7.83	120		y
7				
8				
9				
10	7.84	120		y
11	7.66	120		y
12				
13				
14				
15				
16				
17				
18				
19				
20	7.63	120		y
21	7.69	120		y
22				
23				
24				
25	7.88	120		y
26				
27				
28				
29				
30				
31				

(No = N = Excursion) Total N's ☒

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: April 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.0	
Alk	45.0	(Alkalinity)
PO4	--	(Orthophosphate)
Other	--	()

Eric Carlson 5-2-23

Print Name: Jeffrey A. Morrison

Signature: [Signature]

Date: 5/1/23

Send to DWP within 10 days after end of
sampling period