

Day	pH	Alk	Comments	Y/N
1				
2				
3	7.06	120		y
4				
5				
6				
7				
8				
9	7.09	120+		y
10	7.15	120+		y
11	7.20	120+		y
12	7.10	120+		y
13				
14				
15	7.24	120+		y
16	7.10	120+		y
17				
18				
19	7.13	120		y
20	7.26	-		y
21	7.19	-		y
22	7.16	120		y
23	7.11	120		y
24				
25				
26	7.32	-		y
27	7.11	-		y
28	7.31	-		y
29	7.45	120		y
30	7.44	120		y
31	7.55	120		y

(No = N = Excursion) Total N's 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00508

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: MAY 2023

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.0

Alk 45.0 (Alkalinity)

PO4 -- (Orthophosphate)

Other -- ()

Eric Carlson 6-5-23

Print Name: Eric Carlson

Signature: [Signature]

Date: 6-1-23

Send to DWP within 10 days after end of sampling period