

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Comments	Y/N
1	7.50	120		y
2	7.46	120		y
3				
4				
5	7.54	120		y
6	7.41	120		y
7	7.08	120		y
8	7.06	120		y
9				
10				
11				
12				
13				
14				
15	7.31	120		y
16	7.27	120+		y
17				
18				
19	7.45	120+		y
20				
21	7.57	120+		y
22	7.21	120+		y
23				
24				
25				
26	7.16	120+		y
27	7.23	120+		y
28				
29	7.20	120+		y
30	7.12	140		y
31				

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Marcola Water District

Entry Point: EP-D (Irish Well)

Sample Period: June 2023

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Eric Carlson 7-5-23

Print Name: Jeffrey A. Morrison

Signature: Jeffrey A. Morrison

Date: 7/3/23

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>